

Smart Industrial Energy Management with Remote Access via Modbus

Dr. Swapnil B. Mohod¹, Prof. S.D. Lawange²

¹Electrical Department, Prof. Ram Meghe Institute of Technology and research, Bandera, Amravati

²,Electrical Department, Dr. V. B. Kolte College of Engineering, Malkapur, 443101

DOI: 10.5281/zenodo.19292092

ABSTRACT

Smart Industrial Energy Management systems play a crucial role in reducing power consumption, improving operational efficiency, and enabling real-time monitoring of electrical parameters in industrial environments. This project presents the design and implementation of a Smart Industrial Energy Management System with Remote Access using the Modbus communication protocol [1]. The proposed system continuously monitors key electrical parameters such as voltage, current, power, energy consumption, and power factor from industrial loads using Modbus-enabled energy meters. The collected data is transmitted to a centralized monitoring unit, enabling remote supervision and analysis through a supervisory interface. By utilizing Modbus protocol, the system ensures reliable, standardized, and cost-effective communication between energy meters and control units. The proposed solution helps industries identify energy wastage, optimize load usage, and support informed decision-making for energy conservation. The system is scalable, robust, and suitable for real-time industrial energy monitoring applications without relying on complex IoT infrastructure [2].

Keywords:- Smart Energy Management, Industrial Energy Monitoring, Modbus Protocol, Remote Energy Monitoring, Power Quality Analysis, Energy Metering, Load Management, Industrial Automation, Real-Time Data Acquisition.

1. INTRODUCTION

In modern industrial environments, electrical energy is one of the most critical and costly resources. With the rapid growth of automation, machinery, and continuous production processes, industries face increasing challenges in monitoring, controlling, and optimizing their energy consumption. Inefficient energy usage not only increases operational costs but also leads to power quality issues, equipment stress, and reduced system reliability. Hence, the need for a Smart Industrial Energy Management System (SIEMS) has become essential [5]. Smart Industrial Energy Management focuses on the real-time measurement, analysis, and supervision of electrical parameters such as voltage, current, power, energy consumption, and power factor. By continuously monitoring these parameters, industries can identify excessive energy usage, detect abnormal operating conditions, and improve overall energy efficiency. Remote access capability further enhances the system by allowing operators and engineers to monitor energy data from a centralized location without physically being present at the site [4]. The Modbus communication protocol is widely adopted in industrial automation due to its simplicity, reliability, and compatibility with various industrial devices such as energy meters, PLCs, and controllers. Modbus enables standardized data exchange between field devices and monitoring systems, making it a cost-effective solution for industrial energy monitoring. Its robustness and ease of implementation make it suitable for harsh industrial environments [2].

This project, titled “Smart Industrial Energy Management with Remote Access via Modbus,” aims to design and implement a system that efficiently monitors industrial energy consumption using Modbus-enabled energy meters. The system provides remote access to real-time and historical energy data, enabling better decision-making, load optimization, and preventive maintenance. Unlike complex IoT-based systems, the proposed approach relies on proven industrial communication standards, ensuring stability, scalability, and ease of deployment in real-world industrial applications [2].

1.1 Problem Statement

Industries consume a significant amount of electrical energy for operating machinery, production lines, and auxiliary systems. In many industrial setups, energy monitoring is still carried out using conventional meters and manual data collection methods. These approaches do not provide real-time visibility of energy consumption, making it difficult to identify power wastage, abnormal load conditions, and inefficiencies in the system. As a result, industries face increased operational costs, poor energy utilization, and reduced equipment lifespan [3].

Additionally, the lack of remote access to energy data requires constant physical presence of personnel for monitoring and analysis, which is time-consuming and inefficient. Existing advanced solutions often rely on complex IoT infrastructures that increase system cost, implementation complexity, and maintenance requirements, making them unsuitable for small- and medium-scale industries [4]. Therefore, there is a need for a reliable, cost-effective, and real-time industrial energy monitoring system that can remotely access electrical parameters without relying on complex IoT frameworks. Utilizing a standardized industrial communication protocol such as Modbus can address these challenges by enabling accurate energy data acquisition, remote monitoring, and efficient energy management in industrial environments [20].

1.2. Research Objectives

- **To design a smart energy monitoring system** capable of measuring key electrical parameters such as voltage, current, power, energy consumption, and power factor in industrial loads.
- **To implement Modbus-based communication** for reliable and standardized data exchange between energy meters and the central monitoring unit.
- **To enable remote access and real-time monitoring** of industrial energy data for effective supervision and control without the need for physical presence.
- **To analyze energy consumption patterns** in order to identify power wastage, inefficient load usage, and abnormal operating conditions.
- **To develop a cost-effective and scalable solution** suitable for small- and medium-scale industries without relying on complex IoT infrastructure.
- **To improve energy efficiency and decision-making** by providing accurate and timely energy information to industrial operators and management.

1.3 Motivation

The rapid growth of industrial automation and increasing energy demand have made efficient energy management a critical requirement for modern industries. Electrical energy constitutes a major portion of industrial operating costs, and even small inefficiencies in energy usage can lead to significant financial losses over time. Many industries still rely on conventional energy meters and manual monitoring methods, which do not provide real-time insights into energy consumption or system performance [4]. The motivation for this project arises from the need to reduce energy wastage, improve operational efficiency, and enable informed decision-making in industrial environments. Lack of continuous monitoring and remote accessibility makes it difficult to detect abnormal power usage, equipment overloads, and power quality issues at an early stage. This often results in increased downtime, higher maintenance costs, and reduced equipment life [6]. Furthermore, while advanced IoT-based energy management solutions exist, they are often expensive, complex, and challenging to maintain, especially for small- and medium-scale industries. The Modbus communication protocol, being a well-established and widely used industrial standard, offers a reliable and cost-effective alternative for implementing smart energy management systems [20]. Therefore, this project is motivated by the need to develop a simple, robust, and scalable Smart Industrial Energy Management System with Remote Access via Modbus that helps industries monitor energy usage efficiently, minimize losses, and promote sustainable and economical energy utilization [3].

1.4 Research Gap

Despite significant research and development in industrial energy management systems, several gaps remain in existing approaches. Most conventional industrial energy monitoring solutions focus on basic metering and periodic data collection, which lack real-time analysis and remote accessibility. These systems are insufficient for detecting instantaneous energy wastage, load imbalances, and abnormal operating conditions [2]. Recent studies have increasingly adopted IoT- and cloud-based energy management systems, offering advanced analytics and visualization. However, these solutions introduce challenges such as high implementation cost, increased system complexity, dependency on continuous internet connectivity, cyber security concerns, and limited suitability for small- and medium-scale industries. Additionally, many IoT-based approaches prioritize data transmission over industrial-grade reliability [18]. Another notable gap is the limited use of standardized industrial communication protocols in research-oriented energy management solutions. While Modbus is widely used in industrial automation, its potential for cost-effective remote energy monitoring and management has not been sufficiently explored in many academic and practical implementations. Existing research often lacks focus on simple, robust architectures that align with real industrial environments [17]. Furthermore, several existing systems do not provide adequate support for scalability, interoperability, and easy integration with legacy industrial equipment. There is also limited emphasis on presenting energy data in a way that supports actionable decision-making for operators and maintenance personnel.

Hence, this research addresses these gaps by proposing a Smart Industrial Energy Management System with Remote Access using Modbus, focusing on real-time monitoring, standardized communication, cost-effectiveness, and practical industrial deployment without relying on complex IoT infrastructure [18].

2. LITERATURE REVIEW

1. Wicaksono, R. "IoT Based Smart Energy Meter Using Modbus Protocol as Electricity Saving Effort" Presents a prototype that integrates Modbus-enabled meters with an IoT frontend to provide real-time energy readings and basic analytics aimed at reducing electricity waste. The work discusses implementation details and experimental results from a pilot setup. Presents the design and implementation of a smart energy metering system aimed at improving electricity usage efficiency. The study focuses on integrating a Modbus-enabled energy meter with a data acquisition and monitoring system to collect real-time electrical parameters such as voltage, current, power, and energy consumption. The Modbus protocol is employed due to its simplicity, reliability, and widespread acceptance in industrial and utility applications. The proposed system enables continuous monitoring of energy consumption and transmits the collected data to a higher-level monitoring platform for visualization and analysis. By providing real-time access to consumption data, the system helps users identify inefficient energy usage patterns and take corrective actions to reduce electricity wastage. Experimental results presented in the paper demonstrate accurate data acquisition and stable communication between the energy meter and the monitoring unit [1]. The study highlights that the use of Modbus protocol ensures standardized communication while maintaining low implementation cost. The author concludes that smart energy meters integrated with communication protocols like Modbus can play a significant role in promoting energy conservation and supporting intelligent energy management solutions for residential and small industrial applications [1].

2. Mišljenović, N. et al. *A Review of Energy Management Systems and Organizational Structures of* Comprehensive review of EMS architectures, objectives, and deployment scenarios; useful for mapping industrial EMS requirements and comparing cloud vs. local architectures. Helpful background for justifying non-IoT/modbus approaches in industry. This paper is a comprehensive, state-of-the-art literature review that examines Energy Management Systems (EMS) specifically at the *prosumer* level (households or small entities that both produce and consume energy). The authors survey EMS control/organizational structures, EMS functional elements, forecasting/prediction methods for input parameters (e.g., load, PV generation, market prices), optimization frameworks and algorithms, objective functions and constraints, and the market environment in which prosumers operate. The review is organized to highlight how different organizational models (standalone prosumer, microgrid, prosumer community, aggregator/virtual power plant) affect EMS design and operation. Methodology: the paper performs a systematic literature synthesis across recent journal articles, conference papers, and technical reports to (1) classify EMS architectures and control hierarchies, (2) compare prediction techniques (statistical, machine learning, hybrid), and (3) evaluate optimization frameworks (deterministic, stochastic, robust, multi-objective). The authors pay special attention to uncertainty management (renewable output, demand, prices) and to the role of aggregators and virtual power plants for coordinating multiple prosumers [2].

[3] Singh, R. R. *IoT embedded cloud-based intelligent power quality monitoring*. Presents an advanced framework for monitoring and analyzing power quality (PQ) parameters using embedded systems integrated with cloud computing. The primary objective of the work is to address common power quality issues such as voltage sag, swell, harmonics, interruptions, and transients that adversely affect industrial equipment performance and reliability. The proposed system employs embedded sensing units to continuously measure electrical parameters, including voltage, current, frequency, and harmonic distortion. These measurements are transmitted to a cloud platform using IoT communication technologies, enabling real-time data storage, visualization, and analysis. The system supports event-based logging, allowing pre-event and post-event power quality data to be captured efficiently, which helps in diagnosing disturbances and identifying their root causes. A significant contribution of this paper is the integration of intelligent analytics with cloud infrastructure to improve scalability and accessibility of power quality monitoring. The cloud-based architecture enables remote access to PQ data through dashboards and alerts, facilitating proactive maintenance and faster decision-making. Experimental results demonstrate the system's ability to accurately detect and classify power quality disturbances under different operating conditions [3].

[4] Karafotis, P. A., Georgilakis, P. S. "Power Quality Monitoring and Evaluation in Power Systems under Non-stationary Conditions Using Wavelet Packet Transform" present an advanced analytical approach for monitoring and evaluating power quality (PQ) disturbances in electrical power systems. The paper addresses the limitation of traditional Fourier-based techniques, which are ineffective in accurately analyzing non-stationary and transient PQ events commonly found in modern power systems. The authors propose the use of the Wavelet Packet Transform (WPT) to decompose voltage and current signals into time-frequency components, allowing

precise identification of disturbances such as voltage sags, swells, interruptions, harmonics, and transient events. The WPT-based method provides high time and frequency resolution, enabling effective characterization of short-duration and overlapping PQ disturbances. A key contribution of the paper is the development of quantitative power quality indices derived from wavelet packet energy coefficients. These indices offer an objective and accurate assessment of power quality levels under non-stationary operating conditions. Simulation and experimental results demonstrate that the proposed WPT-based approach outperforms conventional FFT-based methods in detecting and classifying PQ disturbances [4].

[5] Ravi, T. et al. “*Analysis, monitoring, and mitigation of power quality disturbances*” *Frontiers in Energy Research*. Published in *Frontiers in Energy Research*, present a comprehensive study on power quality (PQ) problems commonly encountered in modern electrical power systems, particularly in industrial environments. The paper focuses on identifying the causes, effects, and mitigation strategies for various PQ disturbances. The authors systematically analyze major power quality issues such as voltage sag, voltage swell, harmonics, flicker, interruptions, and transients. The paper reviews different monitoring techniques used to detect these disturbances, including time-domain analysis, frequency-domain methods, and advanced signal processing approaches. Emphasis is placed on continuous monitoring to ensure early detection and accurate diagnosis of PQ events. In addition to monitoring, the study discusses several mitigation techniques such as passive and active filters, dynamic voltage restorers (DVR), uninterruptible power supplies (UPS), and power factor correction methods. The authors highlight that effective mitigation requires accurate identification of disturbance type and severity. Case studies and experimental observations demonstrate how appropriate mitigation strategies can significantly improve power quality and protect sensitive industrial equipment [5].

The paper concludes that an integrated approach combining real-time monitoring, intelligent analysis, and suitable mitigation techniques is essential for maintaining power quality in modern power systems. The authors also point out the need for reliable data acquisition systems and robust communication infrastructures to support effective PQ management.

[6] Golov, R. S. “*Energy Management System for an Industrial Enterprise*” presents a structured framework for designing and implementing an integrated energy management system (EMS) tailored to industrial enterprises. The primary focus of the study is on improving energy efficiency, reducing operational costs, and enhancing energy-related decision-making within manufacturing and industrial organizations. The paper describes the functional components of an industrial EMS, including energy data acquisition, monitoring, analysis, reporting, and control. It emphasizes the importance of collecting accurate real-time data from electrical and thermal energy sources and integrating this data into a centralized management platform. The author also discusses the role of key performance indicators (KPIs) such as energy intensity, specific energy consumption, and efficiency indices in evaluating enterprise energy performance. A significant contribution of the paper is the discussion on organizational and managerial aspects of energy management. The study highlights how EMS implementation should align with enterprise management structures, operational planning, and maintenance strategies. Case-based observations show that a well-designed EMS can lead to measurable reductions in energy consumption and improved equipment utilization. The paper concludes that an effective industrial energy management system must combine technical monitoring infrastructure with organizational processes and decision-support tools. The author stresses that scalability, reliability, and integration with existing industrial systems are critical for successful EMS deployment [6].

[7] Aher, M. V. N. “*Modbus connected Multichannel Parameter Data Acquisition, Monitoring and User Management System*.” presents the design and implementation of a multichannel data acquisition system based on the Modbus communication protocol for industrial monitoring applications. The main objective of the work is to enable simultaneous monitoring of multiple electrical and environmental parameters from different field devices using a standardized and reliable communication framework. The proposed system employs Modbus-enabled sensors and meters connected through an RS-485 communication network to a central data acquisition unit. Multiple parameters such as voltage, current, power, temperature, and other process variables are collected in real time and displayed through a user-friendly monitoring interface. The system also incorporates a user management module, allowing different access levels for operators, supervisors, and administrators, thereby enhancing system security and usability. A key contribution of this paper is its emphasis on scalability and flexibility. The multichannel architecture allows additional devices and parameters to be integrated without significant modification to the existing system. Experimental results presented in the study demonstrate reliable data communication, accurate parameter acquisition, and stable system performance in an industrial-like environment. The paper concludes that Modbus-based multichannel data acquisition systems provide a cost-effective and robust solution for industrial monitoring and management applications. The approach is particularly suitable for small- and medium-scale industries where simplicity, reliability, and ease of expansion are essential [7].

[8] Oluwaleye, S. “*Design and Development of a Remote Monitoring Agent for Energy Services*” presents the development of a software–hardware framework aimed at enabling remote monitoring of energy systems. The

primary goal of the study is to provide continuous visibility of energy-related parameters and system status from geographically distributed energy assets through a centralized monitoring agent. The proposed monitoring agent is designed to collect energy data from local measurement devices, process the information, and transmit it to a remote supervisory platform for visualization and analysis. The system architecture emphasizes modularity, allowing the monitoring agent to interface with different types of energy systems and communication technologies. Real-time data acquisition and remote access features enable operators to monitor performance, detect anomalies, and respond promptly to operational issues. A key contribution of the paper is its focus on system reliability and scalability. The author discusses data handling, communication reliability, and fault tolerance to ensure consistent performance even under varying network conditions. Experimental evaluation demonstrates that the monitoring agent can effectively support real-time supervision and historical data analysis for energy services. The paper concludes that remote monitoring agents play a vital role in improving energy system efficiency, reducing maintenance costs, and supporting proactive decision-making. The study highlights the importance of flexible communication interfaces and robust data management in remote energy monitoring applications [8].

[9] Extraction of Data from an RS-485 enabled Multi-Function Meter, focuses on the practical aspects of acquiring electrical measurement data from multifunction energy meters using the RS-485 communication interface. The study addresses the challenges involved in retrieving accurate real-time electrical parameters from industrial meters and emphasizes the importance of standardized communication protocols for reliable data extraction. The authors describe the hardware and software methodology required to interface RS-485 enabled meters with a data acquisition or monitoring system. The work explains communication setup parameters such as baud rate, parity, slave addressing, and register mapping, which are essential for successful data exchange. Electrical parameters including voltage, current, active and reactive power, energy consumption, and power factor are extracted by reading predefined register addresses from the meter. A key contribution of the paper is the detailed explanation of Modbus RTU communication over RS-485, including frame structure, polling mechanism, and error handling techniques such as CRC checks. Experimental validation demonstrates stable communication and accurate data retrieval under different operating conditions, confirming the suitability of RS-485 for industrial environments. The paper concludes that RS-485 based data extraction provides a cost-effective, noise-immune, and reliable solution for industrial energy monitoring. It serves as a practical reference for implementing real-time energy data acquisition systems [9].

[10] Găitan, V. G. "Modbus RTU Protocol Timing Evaluation for Scattered Holding Register Read and Modbus" presents a detailed performance analysis of the Modbus RTU protocol with a focus on timing behavior during reading of scattered holding registers. The study addresses a practical challenge in industrial communication where required data registers are non-contiguous, leading to increased communication delays and reduced system efficiency. The paper analytically evaluates Modbus RTU frame structure, inter-frame delay, and polling cycle time under different register access strategies. The author compares single-register reads, block reads, and scattered register reads to quantify their impact on communication latency and bus utilization. Experimental results show that improper register access strategies significantly increase response time and reduce overall throughput in real-time monitoring systems. A key contribution of this work is the formulation of timing models that help predict communication delays based on baud rate, frame size, and register distribution. The paper also proposes optimized polling strategies and register grouping techniques to minimize transaction time while maintaining data accuracy and reliability. The study concludes that careful timing evaluation and register mapping are essential for achieving high-performance Modbus RTU implementations, especially in systems requiring real-time data acquisition from multiple industrial devices [10].

3. PROPOSED METHODOLOGY

The proposed methodology for the Smart Industrial Energy Management with Remote Access via Modbus is designed to provide a reliable and cost-effective solution for monitoring and managing electrical energy in industrial environments. The system utilizes Modbus-enabled multifunction energy meters installed at key distribution points to continuously measure electrical parameters such as voltage, current, power, energy consumption, frequency, and power factor. These meters communicate with a central monitoring unit through an RS-485 network using the Modbus RTU protocol, ensuring standardized and robust data exchange suitable for harsh industrial conditions. The central monitoring unit functions as the Modbus master, periodically polling the connected energy meters to acquire real-time and historical energy data. The collected data is processed, scaled, and time-stamped before being stored in a local database for further analysis. Basic analytical techniques are applied to evaluate energy consumption patterns, detect abnormal load behavior, and identify power quality issues. This enables timely identification of energy wastage and inefficient operation [10].

To enable remote access, the processed energy data is presented through a supervisory interface such as an HMI, SCADA system, or web-based dashboard. Authorized users can remotely monitor real-time energy parameters and review historical reports without the need for physical presence at the industrial site. The proposed methodology emphasizes scalability, allowing additional meters and monitoring points to be integrated easily into the Modbus network. By avoiding complex IoT infrastructure and relying on a proven industrial communication protocol, the system ensures high reliability, low implementation cost, and practical applicability for small- and medium-scale industries [18].




Fig 1: Block diagram

4. LIMITATIONS

- **Limited Communication Speed**
Modbus RTU over RS-485 operates at relatively low data rates compared to modern Ethernet- or cloud-based systems. This may limit performance when a large number of meters are polled frequently.
- **Scalability Constraints**
Although Modbus supports multiple slave devices, performance may degrade as the number of connected meters increases due to increased polling time and bus traffic.
- **Basic Data Analytics**
The system primarily focuses on monitoring and data acquisition. Advanced analytics such as predictive energy optimization, AI-based forecasting, or automated decision-making are not inherently supported.
- **Limited Cyber security Features**
Modbus protocol does not provide built-in encryption or authentication mechanisms, making the system vulnerable if deployed over unsecured networks without additional protection layers.
- **Dependence on Wired Communication**
RS-485 wiring requires proper installation and maintenance. Long cable runs or poor termination may introduce communication errors in harsh industrial environments.
- **No Automatic Control Action**
The proposed system mainly provides monitoring and reporting. Automatic load control or corrective actions require additional control logic and hardware integration.
- **Vendor-Specific Register Mapping**
Different energy meters may use different Modbus register maps, requiring customization during integration and increasing configuration complexity.

5. CONCLUSION

The Smart Industrial Energy Management with Remote Access via Modbus system presented in this project offers a practical and reliable solution for monitoring and managing electrical energy in industrial environments.

By utilizing Modbus-enabled energy meters and RS-485 communication, the system ensures standardized, robust, and cost-effective data acquisition suitable for real-world industrial applications. Continuous monitoring of key electrical parameters such as voltage, current, power, energy consumption, and power factor enables industries to gain clear visibility into their energy usage [9]. The proposed system successfully provides remote access to real-time and historical energy data through a centralized supervisory interface, reducing the need for manual meter readings and on-site supervision. This facilitates informed decision-making, early detection of abnormal operating conditions, and identification of energy wastage. Unlike complex IoT-based solutions, the use of Modbus protocol simplifies implementation while maintaining industrial reliability and scalability [20].

6. REFERENCES

- [1] Wicaksono, R. *IoT Based Smart Energy Meter Using Modbus Protocol as Electricity Saving Effort*. Atlantis Press / conference paper, 2022
- [2] Mišljenović, N. et al. *A Review of Energy Management Systems and Organizational Structures of Prosumers*. Energies (MDPI), 2023
- [3] Singh, R. R. "IoT embedded cloud-based intelligent power quality monitoring" (Science Direct / Elsevier), 2020.
- [4] Karafotis, P. A., Georgilakis, P. S. "Power Quality Monitoring and Evaluation in Power Systems under" Non-stationary Conditions Using Wavelet Packet Transform. IET / Power Quality journal, 2019.
- [5] Ravi, T. et al. "Analysis, monitoring, and mitigation of power quality disturbances. Frontiers in Energy Research" 2022.
- [6] Golov, R. S. "Energy Management System for an Industrial Enterprise" Springer (journal article), 2021
- [7] Aher, M. V. N. "Modbus connected Multichannel Parameter Data Acquisition, Monitoring and User" MDPI 2020
- [8] Oluwaleye, S. "Design and Development of a Remote Monitoring Agent for Energy Services" F1000Research, 2022, 2018
- [9] Găitan, V. G. "Modbus RTU Protocol Timing Evaluation for Scattered Holding Register Read and ModbusE-related Implementation" MDPI / Processes, 2025
- [10] Bastidas, A. J. C. "Performance evaluation of Modbus and DNP3 protocols in TCP under Wi-Fi and Ethernet for micro grids" Science Direct, 2024
- [11] Hosseinzadeh, N. "A Real-Time Monitoring Platform for Distributed Energy Resources" (DER). MDPI / Electronics, 2021.
- [12] Găitan, V. G., et al. "Experimental Implementation and Performance Evaluation of MODBUS CAN". PMC / Sensors, 2021
- [13] Tripathi, S. K. "ESP32-Based Prepaid Electricity Energy Meter with Cloud Interface" SCITEPRESS (conference paper), 2025
- [14] Rahul et al. "Multichannel Data Acquisition and Monitoring System with Modbus" (case study). International Pubs, 2022.
- [15] Ventuneac, C. "Improving Modbus Extension Performance using PRU unit" DAS Conference proceedings, 2022
- [16] ResearchGate / Various authors "Solutions for Monitoring and Remote Control Based on Modbus RTU and S7-1200 PLC" Conference paper, 2019.
- [17] Karim Alami et al. "Modbus security & application reviews" IJIRT / IJ conferences, 2018.
- [18] Andrei, M. et al "Design of a Conceptual Framework Using IoT and Big Data" Research Gate / conference article, 2021
- [19] IJRPR "Design of a Remote Monitoring System for Solar Thermal/Diesel Units" IJRPR PDF, 2021.
- [20] YMER "Digital / IoT-Integrated Smart Energy Metering System" Trade/technical article & system blueprint, 2024
- [21] Power Quality Assessment for an Industrial Plant SciSpace / conference article, 2018
- [22] ResearchGate / Data Retrieval from RS-485 Implemented Energy Meter, 2022. (Authors: various student/institutional works).
- [23] Research & Market / Industry report "Industrial Energy Management Systems Market Analysis" ResearchAndMarkets, 2024.
- [24] R. R. Singh, S. S. Rattan, and S. N. Singh, "IoT embedded cloud-based intelligent power quality monitoring system," *IEEE Trans. Ind. Informatics*, vol. 16, no. 3, pp. 1681–1690, 2020.
- [25] N. Mišljenović, A. Ristić, and S. Stankovski, "A review of energy management systems and organizational structures of prosumers," *Energies*, vol. 16, no. 4, pp. 1–22, 2023