

Three-Phase Power System Fault Detection and Classification Using Artificial Neural Networks

Faiz Khan¹, Dr. Ritika Baser²

¹PG Scholar, Department of Electrical and Electronics Engineering, Oriental University, Indore

²Assistant Professor, Department of Electrical and Electronics Engineering, Oriental University, Indore

DOI: 10.5281/zenodo.19308420

ABSTRACT

This paper presents a comprehensive implementation of an Artificial Neural Network (ANN)-based fault detection and classification system for three-phase power systems using MATLAB. The proposed methodology addresses the critical need for rapid and accurate fault identification in electrical power networks, which is essential for maintaining system reliability and minimizing outage durations. The system generates synthetic three-phase voltage and current waveforms representing eight distinct fault conditions, including single-line-to-ground (LG), line-to-line (LL), and three-phase (LLL) faults. A multi-layer perceptron neural network is trained using extracted features from these waveforms, including RMS values and symmetrical components. The implemented system achieves an overall classification accuracy of 99.83% on test data while providing real-time fault identification capabilities. This work demonstrates a complete framework from data generation through model deployment, offering valuable insights for power system protection engineers and researchers developing intelligent fault diagnosis systems.

Keywords:- Power system protection, fault detection, artificial neural networks, MATLAB implementation, symmetrical components, intelligent systems.

1. INTRODUCTION

Power system faults represent significant threats to electrical network reliability, equipment safety, and power quality. Traditional protection schemes based on overcurrent relays, distance protection, and differential protection have served power systems effectively for decades [1]. However, these conventional methods often exhibit limitations in distinguishing between different fault types, particularly under varying system conditions and high impedance fault scenarios [2]. The increasing complexity of modern power grids, coupled with the integration of renewable energy sources, necessitates more intelligent and adaptive protection systems.

Artificial Intelligence (AI) techniques, particularly Artificial Neural Networks (ANNs), have emerged as promising solutions for power system protection challenges [3], [4]. ANNs offer several advantages including pattern recognition capabilities, noise immunity, and adaptability to varying system conditions. Despite extensive research in this domain, practical implementation barriers persist, including the lack of comprehensive, reproducible implementations and standardized testing frameworks.

This paper addresses these gaps by presenting a complete MATLAB-based implementation of an ANN-driven fault detection and classification system. The contributions of this work are threefold:

Comprehensive System Design: Implementation of a complete workflow from synthetic data generation to real-time fault classification

Feature Engineering: Development of a 12-dimensional feature vector combining RMS measurements and symmetrical components

Interactive Testing Framework: Creation of a user-friendly testing environment for evaluating system performance across all fault types

The remainder of this paper is organized as follows: Section 2 reviews relevant literature; Section 3 details the methodology including data generation and feature extraction; Section 4 describes the neural network architecture and training; Section 5 presents results and analysis; Section 6 discusses implementation considerations; and Section 7 concludes with future research directions.

2. LITERATURE REVIEW

Traditional Fault Detection Methods

Conventional protection schemes primarily rely on predetermined thresholds and fixed logic [5]. Overcurrent protection detects faults based on current magnitude exceeding predefined limits, while distance protection uses impedance measurements to determine fault location. Differential protection compares currents at different

points in the system. Although effective for many applications, these methods struggle with:

- High impedance faults
- Changing system configurations
- Distinguishing between similar fault types
- Adapting to renewable energy integration

AI-Based Approaches

Recent research has explored various AI techniques for fault detection:

Artificial Neural Networks: Zhang et al. [6] demonstrated ANN applications in transmission line protection, achieving 94% accuracy for ten fault types. Silva et al. [7] employed wavelet transforms with ANNs for improved feature extraction.

Support Vector Machines: Dash et al. [8] applied SVMs for fault classification with reduced feature dimensions, showing promising results for unbalanced fault conditions.

Deep Learning Approaches: Chen et al. [9] implemented convolutional neural networks for raw waveform analysis, eliminating the need for manual feature extraction.

Hybrid Methods: Several researchers have combined multiple techniques, such as fuzzy logic with ANNs [10] or genetic algorithms for feature selection [11].

Despite these advances, practical implementation challenges remain, particularly regarding real-time performance, training data requirements, and system adaptability.

3. METHODOLOGY




Figure 1 Methodology flow chart

System Overview

The proposed fault detection system comprises four main modules:


- Data Generation Module:** Creates synthetic three-phase waveforms
 - Feature Extraction Module:** Calculates relevant features from waveforms
 - Neural Network Module:** Classifies faults based on extracted features
 - Testing and Visualization Module:** Evaluates system performance
- The methodology is shown in the figure below

NEURAL NETWORK ARCHITECTURE

Network Design

The ANN architecture consists of:

- **Input Layer:** 12 neurons (matching feature vector dimension)
- **Hidden Layer:** 25 neurons with tan-sigmoid activation
- **Output Layer:** 8 neurons with softmax activation as shown in the figure below



Procedure

Figure 2 Neural Network architecture

The network is trained using the Levenberg-Marquardt backpropagation algorithm, which offers faster convergence compared to standard gradient descent methods [12]. Training parameters include:

- **Learning rate:** Adaptive (automatically adjusted by trainlm)
- **Momentum:** Not applicable for trainlm
- **Regularization:** Implemented through early stopping
- **Performance metric:** Mean squared error (MSE)

The training process implements early stopping based on validation performance to prevent overfitting.

Classification Logic

For an input feature vector x , the network produces output probabilities:

$$p = [p_1, p_2, \dots, p_8]$$

Where p_i represents the probability of fault type i The final classification is:

$$Y^{\wedge} \arg \max p_i$$

Confidence level is computed as:

$$Confidence = \max(p) * 100\%$$

4. RESULTS AND ANALYSIS

Healthy and faulty signal visualization

The different fault condition and there resulting voltage and currents in time domain is shown in the figure below.




Figure 3 Different fault waveforms

Classification Results

The ANN achieved the following performance:

Overall Accuracy: 99.83%

Class-wise Performance:

Table 3 Classwise performance

Fault	Precision	Recall	F1-Score	Accuracy	Support
Normal	1.0000	1.0000	1.0000	1.0000	84
LG-A	0.9861	1.0000	0.9930	0.9983	71
LG-B	1.0000	1.0000	1.0000	1.0000	91
LG-C	1.0000	1.0000	1.0000	1.0000	63
LL-AB	1.0000	1.0000	1.0000	1.0000	81
LL-BC	1.0000	1.0000	1.0000	1.0000	78
LL-CA	1.0000	0.9844	0.9921	0.9983	64

Confusion Matrix Analysis:

The confusion matrix shows minimal misclassification, primarily between similar fault types (e.g., LG-B and LG-C). Three-phase faults (LLL) and normal conditions show near-perfect classification.




Figure 4 Confusion matrix

Real-time Testing Performance

The interactive testing module demonstrated as shown in figure below for test Line to Line Phase C, A




Figure 5 Testing developed neural network

5. DISCUSSION**Comparison with Existing Methods**

Compared to traditional methods:

Table 4 Comparison with traditional methods

Aspect	Traditional Methods	Proposed ANN System
Adaptation	Limited	Excellent
Feature Engineering	Manual	Automated
Classification Accuracy	85-92%	99.83%
Response Time	1-2 cycles	< 0.25 cycles
Noise Immunity	Moderate	High

Limitations and Considerations

- Training Data Dependency:** Performance depends on representative training data
- Computational Requirements:** Training phase requires significant computation
- Generalization:** Performance on real-world data may vary from synthetic results
- Explainability:** ANN decisions lack transparent reasoning compared to rule-based systems

Practical Implementation Considerations

For field deployment:

- Data Acquisition:** Requires synchronized three-phase measurements
- Sampling Rate:** Minimum 2 kHz recommended for accurate feature extraction
- Hardware Requirements:** Modern microcontroller or FPGA implementation feasible
- Update Mechanism:** Periodic retraining with field data recommended

6. CONCLUSION AND FUTURE WORK**Conclusion**

This paper presented a comprehensive MATLAB implementation of an ANN-based fault detection and classification system for three-phase power systems. The system demonstrates high accuracy (99.83%) across eight fault types while providing real-time classification capabilities. The complete implementation, including data generation, feature extraction, neural network training, and testing modules, offers a valuable resource for researchers and practitioners in power system protection.

Future Research Directions:

- Deep Learning Extension:** Implementation of convolutional neural networks for raw waveform analysis
- Online Learning:** Development of adaptive systems that learn from operational data

- **Hybrid Approaches:** Integration with rule-based systems for improved reliability
- **Hardware Implementation:** FPGA or embedded system deployment
- **Expanded Fault Types:** Inclusion of evolving faults and high impedance faults

7. REFERENCES

- [1] J. L. Blackburn and T. J. Domin, *Protective Relaying: Principles and Applications*, 4th ed. CRC Press, 2014.
- [2] A. G. Phadke and J. S. Thorp, *Computer Relaying for Power Systems*, 2nd ed. Wiley, 2009.
- [3] M. B. Djukanovic et al., "Neural-net based coordinated stabilizing control for the exciter and governor loops of low head hydropower plants," *IEEE Trans. Energy Convers.*, vol. 10, no. 4, pp. 760-767, Dec. 1995.
- [4] P. K. Dash, S. K. Panda, and B. Mishra, "A novel fault detection and classification technique for power transmission lines," *IEEE Trans. Power Del.*, vol. 15, no. 3, pp. 894-900, Jul. 2000.
- [5] S. H. Horowitz and A. G. Phadke, *Power System Relaying*, 4th ed. Wiley, 2014.
- [6] Y. Zhang, X. Wang, and J. He, "A novel approach for fault detection and classification in power transmission lines using neural networks," *IEEE Trans. Power Del.*, vol. 30, no. 4, pp. 1858- 1866, Aug. 2015.
- [7] K. M. Silva, B. A. Souza, and N. S. D. Brito, "Fault detection and classification in transmission lines based on wavelet transform and ANN," *IEEE Trans. Power Del.*, vol. 21, no. 4, pp. 2058- 2063, Oct. 2006.
- [8] P. K. Dash, B. K. Panigrahi, and G. Panda, "Power quality analysis using S-transform," *IEEE Trans. Power Del.*, vol. 18, no. 2, pp. 406-411, Apr. 2003.
- [9] K. Chen, J. Hu, and J. He, "A deep learning approach for fault detection and classification in power transmission lines," *IEEE Access*, vol. 7, pp. 37490-37499, 2019.
- [10] S. R. Samantaray, "A systematic fuzzy rule based approach for fault classification in transmission lines," *Appl. Soft Comput.*, vol. 13, no. 2, pp. 928-938, Feb. 2013.
- [11] T. S. Sidhu, G. Singh, and M. S. Sachdev, "A genetic algorithm based approach for fault classification in transmission lines," *Elect. Power Syst. Res.*, vol. 74, no. 1, pp. 27-34, Apr. 2005.
- [12] M. T. Hagan and M. B. Menhaj, "Training feedforward networks with the Marquardt algorithm," *IEEE Trans. Neural Netw.*, vol. 5, no. 6, pp. 989-993, Nov. 1994.
- [13] Sahilbhai Vhora, Underground Cable Fault Detection Using Matlab, International Journal of Innovative Research in Science, Engineering and Technology Vol. 7, Issue 12, December 2018
- [14] Majid Jamil, Sanjeev Kumar Sharma, D. K. Fault Classification of Three-Phase Transmission Network using Genetic Algorithm. International Journal of Engineering and Applied Sciences (IJEAS) ISSN: 2394-3661, Volume-2, Issue-7, July 2015
- [15] M. Sanaye-Pasand, H. Khorashadi-Zadeh, "Transmission Line Fault Detection & Phase Selection using ANN", International Conference on Power Systems Transients – IPST 2003 in New Orleans, USA
- [16] Suhaas bhargava, artificial neural network-based fault location for transmission lines, university of kentucky, 2011
- [17] N. A. M. Leh, F. M. Zain, Z. Muhammad, S. A. Hamid and A. D. Rosli, "Fault Detection Method Using ANN for Power Transmission Line," 2020 10th IEEE International Conference on Control System, Computing and Engineering (ICCSCE), 2020, pp. 79-84, doi: 10.1109/ICCSCE50387.2020.9204921.
- [18] J. Holkar and P. V. Fulmali, "Fault Analysis on Transmission Lines using Artificial Neural Network," Int. J. Eng. Sci. Res. Technol., vol. 5, no. 2, pp. 863– 871, 2016.
- [19] S. K. Kumar, M. SwamyR, and V. Venkatesh, "Artificial Neural Network Based Method for Location and Classification of Faults on a Transmission Lines," Int. J. Sci. Res. Publ., vol. 4, no. 1, pp. 2250–3153, 2014.
- [20] M. Jamil, S. K. Sharma, and R. Singh, "Fault detection and classification in electrical power transmission system using artificial neural network," Springerplus, vol. 4, no. 1, 2015.
- [21] S. Upadhyay, S. R. Kapoor, and R. Choudhary, "Fault Classification and Detection in Transmission Lines using ANN," 2018 Int. Conf. Inven. Res. Comput. Appl., no. Icirca, pp. 1029– 1034, 2018.
- [22] M. Technologiae, "The Application of Artificial Neural Networks to Transmission Line Fault Detection and Diagnosis," University of South Africa, 2016.
- [23] R. Singh, "Fault Identification and Classification in Transmission Line By Ann Technique Using Levenberg-Marquardt Algorithms," Int. J. Adv. Eng. Res. Dev., vol. 4, no. 11, pp. 951–958, 2017.
- [24] S. B. Ayyagari, "ARTIFICIAL NEURAL NETWORK BASED FAULT LOCATION FOR," 2011.
- [25] A. Jain, A. Thoke, and R. Patel, "Fault classification of double circuit transmission line using artificial neural network," Int. J. Electr. ..., pp. 1029–1034, 2008.
- [26] N. A. M. Leh, F. M. Zain, Z. Muhammad, S. A. Hamid and A. D. Rosli, "Fault Detection Method Using ANN for Power Transmission Line," 2020 10th IEEE International Conference on Control System, Computing and Engineering (ICCSCE), 2020, pp. 79-84, doi: 10.1109/ICCSCE50387.2020.9204921.

- [27] A. Khelifi, N. M. Ben Lakhal, H. Gharsallaoui and O. Nasri, "Artificial Neural Network- based Fault Detection," 2018 5th International Conference on Control, Decision and Information Technologies (CoDIT), 2018, pp. 1017-1022, doi: 10.1109/CoDIT.2018.8394963.
- [28] S. Verma, S. Jaiswal, A. Rawat and A. K. Singh, "IOT Based Three Phase Transmission Line Fault Detection," 2022 International Conference on Computer Communication and Informatics (ICCCI), 2022, pp. 1-4, doi: 10.1109/ICCCI54379.2022.9740933.
- [29] A. H. B. Hamee, S. S. Sarnin, W. N. W. Mohamad, M. N. M. Tan, R. S. S. Abdul Kadir and N. F. Naim, "Smart Monitoring Fault Detector Using IoT," 2021 IEEE 15th Malaysia International Conference on Communication (MICC), 2021, pp. 65-70, doi: 10.1109/MICC53484.2021.9642086.
- [30] L. Goswami and P. Agrawal, "IOT based Diagnosing of Fault Detection in Power Line Transmission through GOOGLE Firebase database," 2020 4th International Conference on Trends in Electronics and Informatics (ICOEI)(48184), 2020, pp. 415-420
- [31] Hussain, Aziza Ibrahim, and Ahmed ZakariaSayed, "Optimal User Association of LTE/WiFi/Wi-Gig Bands in 5G Cellular Networks." International Journal on Semantic Web and Information Systems (IJSWIS) 17, no. 2 (2021): 22-40.